



BRANZ Appraised

Appraisal No. 648 [2022]

KNAUF GLASSWOOL INSULATION

Appraisal No. 648 [2022]

This Appraisal replaces BRANZ Appraisal No. 648 [2016]

Amended 01 September 2026



BRANZ Appraisals

Technical Assessments of products for building and construction.



Knauf Insulation Pty Limited

23 Corporate Drive
Cannon Hill
Queensland 4170
Australia

Tel: + 61 7 3343 1989

Web: www.knaufinsulation.com.au



BRANZ

1222 Moonshine Rd,
RD1, Porirua 5381
Private Bag 50 908
Porirua 5240,
New Zealand
Tel: 04 237 1170
branz.co.nz



Product

1.1 Knauf Glasswool Insulation is a range of thermal insulating materials manufactured from ECOSE® Technology resin-bonded, glass wool fibres and contains DriTherm® Technology which is a silicon treatment. The insulation is pre-cut to suit a range of thermal insulation requirements and framing set-outs in walls, ceilings and roofs of buildings. The following Knauf Glasswool Insulation products are covered by this Appraisal:

- Knauf Insulation
- Earthwool® Glasswool Insulation
- **eco**insulation Glasswool Insulation

Scope

2.1 Knauf Glasswool Insulation has been appraised as a thermal insulating material for framed or part-framed walls, ceilings and roofs of domestic and commercial buildings.

Building Regulations

New Zealand Building Code (NZBC)

3.1 In the opinion of BRANZ, Knauf Glasswool Insulation, if designed, used, installed and maintained in accordance with the statements and conditions of this Appraisal, will meet or contribute to meeting the following provisions of the NZBC:

Clause B2 DURABILITY: Performance B2.3.1 (a) not less than 50 years and B2.3.1 (b) 15 years. Knauf Glasswool Insulation meets these requirements. See Paragraphs 8.1 and 8.2.

Clause E3 INTERNAL MOISTURE: Performance E3.3.1. Knauf Glasswool Insulation contributes to meeting this requirement. See Paragraphs 13.1 and 13.2.

Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.1. Knauf Glasswool Insulation meets this requirement.

Clause H1 ENERGY EFFICIENCY: Performance H1.3.1 (a) and H1.3.2 E. Knauf Glasswool Insulation contributes to meeting these requirements. See Paragraphs 14.1 and 14.2.

Technical Specification

4.1 Knauf Glasswool Insulation is an ECOSE® Technology resin-bonded, fibrous glass wool insulation and contains DriTherm® Technology, which is a silicon treatment. It is manufactured from recycled and/or virgin glass and ECOSE® Technology resin and formed into segments, blankets and rolls. Knauf Glasswool Insulation is available as set out in Table 1.

Table 1: Knauf Glasswool Insulation product ranges

	Product Code	R-value	Nominal Thickness [mm]	Width [mm]	Length [mm]	Density [kg/m³]
Earthwool Glasswool	Wall Segments					
	781975	1.3	45	450	1,160	20.5
	683644	2.2	90	580	1,160	11
	683645	2.4	90	580	1,160	14.6
	683655	2.6	90	430	1,160	20
	683656	2.6	90	580	1,160	20
	683646	2.8	90	430	1,160	30.7
	683647	2.8	90	580	1,160	30.7
	683648	3.2	140	580	1,160	9.3
	683641	3.6	140	580	1,160	13.4
	691267	4.1	140	580	1,160	22.6
	779911	4.4	140	580	1,160	36
	Perimeter Segment					
	812468	3.4	110	580	1,160	30.2
	Ceiling Segment					
	731850	3.6	175	430	1,160	7.4
	731846	4.1	195	430	1,160	7.7
	683653	5.2	210	430	1,160	11.4
	779551	7	330	460	1,200	8
	779554	8	330	460	1,200	11
	Ceiling Roll					
	690936	3.6	150	1,200	7,000	11
	Skillion Roof					
	683642	3.2	105	430	1,160	26.5
	779683	5	165	430	1,160	29
	781973	6	215	430	1,160	17.5
	781979	7.4	265	430	1,160	18
Knauf Insulation	Wall Segments					
	888520 860162	2.2	90	580	1,160	11
	860160	2.4	90	580	1,160	14.6
	860158	2.6	90	430	1,160	20.1
	860156	2.6	90	580	1,160	20.1
	860152	2.8	90	430	1,160	32
	860150	2.8	90	580	1,160	32
	860148	3.2	140	580	1,160	9.3

Knauf Insulation	860140	4.1	140	580	1,160	22.6
	860136	4.4	140	580	1,160	36
	Multi-Use Roll					
	807198	2.6	90	430	8,500	20
	807200	2.6	90	580	8,500	20
	Roof Blanket					
	823136	2.6	105	1,200	16,500	11.4
	683667	3.1	120	1,200	14,500	12.8
	Ceiling Segment					
	860144	3.6	170	430	1,160	8.3
	860138	4.2	210	430	1,160	7.8
	860132	5.2	230	430	1,160	8.7
	860128	7	330	460	1,160	8
	Skillion Roof					
	860164	1.3	45	450	1,160	20.5
	860146	3.4	110	580	1,160	30.2
	860134	5	165	430	1,160	29
	860130	6	215	430	1,160	17.5
	860126	7.4	265	430	1,160	18
ecoinsulation	Wall Segments					
	888522	2.2	90	580	1,160	11
	683707	2.4	90	570	1,160	14.6
	707756	2.6	90	430	1,160	20.5
	874216	2.6	90	570	1,160	20.1
	874532	2.8	90	570	1,160	30.7
	874631	3.2	140	570	1,160	9.4
	683709	3.6	140	570	1,160	13.4
	874218	4.1	140	570	1,160	22.6
	874220	4.4	140	570	1,160	36
	Ceiling Segments					
	683700	3.6	160	430	1,160	9.1
	683702	4.2	180	430	1,160	10.1
	779548	7	330	460	1,200	8
	Skillion Roof					
	874222	1.3	45	570	11,500	20.5
	872716	5	165	570	1,160	29
	872841	6	215	570	1,160	17.5
	872718	7.4	265	570	1,160	18

- 4.2 Knauf Glasswool Insulation is brown in colour and is packaged in pre-printed plastic compression bags with labelling in compliance with AS/NZS 4859.1.
- 4.2 Accessories used with Knauf Glasswool Insulation, which are supplied by the insulation installer, are plastic strapping and fixings.
- 4.3 Knauf Glasswool Insulation Acoustic insulation is available as set out in Table 2. [Note: These products have not been tested to AS/NZS 4859.1.]

Table 2: Earthwool Glasswool Insulation Acoustic insulation product range

Product Code	Thickness [mm]	Width [mm]	Length [mm]	Density [kg/m³]
883477	50	600	2,700	11
882264	75	600	2,700	11

Handling and Storage

- 5.1 Knauf Glasswool Insulation must be stored under cover and in dry conditions. Heavy objects must not be stacked on the packs. The packs must be stored in an orientation that avoids excessive compression of the product.
- 5.2 In general, insulation products are sensitive to the length of time they are stored under compression packaging. Product that does not recover to its nominal thickness may not achieve the stated thermal resistance [R-value].

Technical Literature

- 6.1 This Appraisal must be read in conjunction with:

Knauf Insulation

- Knauf Insulation: Wall Datasheet, version KINZ11241520DS [v0.4], dated June 2025.
- Knauf Insulation: Wall Installation Instructions, version KINZ10241481INS [v0.5].
- Knauf Insulation: R1.3 Installation Instructions, version KINZ10241480INS [v0.2].
- Knauf Insulation: Multi-Use Roll Datasheet, version KINZ08241435 [v0.5], dated March 2026.
- Knauf Insulation Multi-Use Roll Installation Instructions, version KINZ08241439MIS [v0.3].
- Knauf Insulation: Roof Blanket Datasheet, version KINZ0914115DS [v0.6], dated October 2024.
- Knauf Insulation: Ceiling/Skillion Roof Datasheet, version KINZ10241487DS [v0.7], dated September 2025.
- Knauf Insulation: Ceiling Installation Instructions, version KINZ10241483INS [v0.2].
- Knauf Insulation: Ceiling R7.0 Installation Instructions, version KINZ10241482INS [v0.2].

Earthwool Glasswool Insulation

- Earthwool® Glasswool Insulation: Wall Datasheet, version KINZ0914114DS [v0.13], dated July 2025.
- Earthwool® Glasswool Insulation: Wall Installation Instructions, version KINZ1017633MIS [v0.4].
- Earthwool® Glasswool Insulation: R1.3 Installation Instructions, version KINZ11221277MIS [v0.3].
- Earthwool® Glasswool Insulation: Ceiling/Skillion Roof Datasheet, version KINZ1213029DS [v0.15], dated July 2025.
- Earthwool® Glasswool Insulation: Ceiling Installation Instructions, version KINZ1018632MIS [v0.3].

ecoinsulation Glasswool Insulation

- ecoinsulation Thermal and Acoustic Wall Datasheet, version EINZ04251605DS [v0.17], dated November 2025.
- ecoinsulation Thermal and Acoustic Wall Installation Instructions, version KINZ1218806MIS.
- ecoinsulation Thermal Ceiling and Skillion Roof Datasheet, version EINZ04251604DS [v0.14], dated July 2025.
- ecoinsulation Thermal Ceiling Installation Instructions, version KINZ1218808MIS.
- ecoinsulation® with DriTherm® Technology - Thermal Ceiling R7.0, version EISL10221000MIS.

- 6.2 All aspects of design, use, installation and maintenance contained in the Technical Literature and within the scope of this Appraisal must be followed.

Design Information

General

- 7.1 Knauf Glasswool Insulation is intended for use as thermal insulation to meet the requirements of the NZBC. Knauf Glasswool Insulation can be used to meet the requirements of the NZBC Verification Methods H1/VM1, H1/VM2, NZBC Acceptable Solutions H1/AS1 or H1/AS2. Greater construction R-values can be achieved where specific design is used. For construction R-values, refer to the BRANZ House Insulation Guide. Product R-values and dimensions are given in Table 1.
- 7.2 The R-value of Knauf Glasswool Insulation has been determined by testing to AS/NZS 4859.1.
- 7.3 Knauf Glasswool Insulation is designed to be friction-fitted between wall, ceiling or roof framing. It can also be laid directly on a ceiling lining, over ceiling battens or joist/truss chords. In other horizontal situations, the insulation must be adequately supported by a suitable durable material. Earthwool® Glasswool skillion roof insulation is designed to be friction-fitted between rafters.
- 7.4 For new and existing buildings, the R7 and R8 ceiling products are designed to be friction-fitted between framing and spill above the framing to form a uniform insulation layer on the top.
- 7.5 When insulation is installed in a double layer over new or existing insulation, the possibility of compression of the bottom layer must be avoided, or reduction of R-values for the bottom layer of the formed system must be taken into account.
- 7.6 Where the insulation is installed in exterior walls, the nominal thickness of the insulation material must be selected to provide a snug close fit, which touches all sides of the insulation cavity between the wall underlay and the interior wall lining.
- 7.7 Where the insulation is retrofitted in external walls without a wall underlay, and with direct-fixed claddings, the insulation must be at least 20 mm thinner than the framing to allow a gap of at least 20 mm between the insulation and the wall cladding. Horizontal straps must be stapled into the sides of the wall studs at 300 mm centres maximum as support before the insulation is installed. Refer also to NZS 4246.
- 7.8 Where the insulation is installed in a wall with a drained cavity, it is recommended that specific wall products with a controlled nominal thickness be used. Where the stud spacings are greater than 450 mm, an intermediate means of restraining the insulation from bulging into the cavity must be installed in accordance with NZBC Acceptable Solution E2/AS1.
- 7.9 To prevent moisture transfer and to provide roof ventilation, a separation of 25 mm minimum is required between the insulation and any rigid substrate or flexible roof underlay. Selecting specifically designed skillion roof insulation products with a controlled thickness can assist with this requirement.
- 7.10 The building envelope must be constructed to ensure the insulation remains dry during installation and throughout the life of the building.
- 7.11 The clearance requirements for heating appliances and downlights must be met and reference made to the manufacturers instructions and NZS 4246.

Durability

- 8.1 The durability assessment of Knauf Glasswool Insulation to meet the requirements of the NZBC is based on the difficulty of access and replacement, and the ability to detect failure of the insulation, both during normal use and maintenance of the building.

Serviceable Life

- 8.2 Where the building is maintained so that provisions of the NZBC Clauses E2 and E3 are met, and where the insulation is not crushed or exposed to conditions that will diminish its thermal performance [e.g. moisture], Knauf Glasswool Insulation can expect to have a serviceable life of at least 50 years.

Maintenance

- 9.1 Insulation that has become damp must be removed and the cause of dampness repaired. Cavities must be clean and dry before fitting new insulation of an equivalent thermal rating. NZS 4246 gives guidance on thermal insulation maintenance due to water damage.
- 9.2 Earthwool® Glasswool Insulation with DriTherm® Technology may be dried and retrofitted into the dried cavity if the cause of dampness was a potable water leak.

Prevention of Fire Occurring

- 10.1 Knauf Glasswool Insulation has been classified as a non-combustible material and need not be separated from heat sources such as fireplaces, heating appliances and chimneys. However, when used in conjunction with, or attached to heat sensitive materials, the heat sensitive material must be separated or protected from heat sources. NZBC Acceptable Solution C/AS1 and C/AS2 provide methods for separation and protection of combustible materials from heat sources.

Downlights

- 10.2 Insulation should maintain 100 mm clearance from all undefined recessed luminaires, treating them as a heat source. For insulation to abut or cover recessed luminaires these must be clearly marked as being suitable for having insulation abutting or covering them and have been installed in accordance with NZBC Acceptable Solution G9/AS1.

Fire Affecting Areas Beyond the Fire Source

Control of Internal Fire and Smoke Spread

- 11.1 Knauf Glasswool Insulation has been tested to AS 1530.1 and classified as non-combustible and has been assessed to achieve the equivalent of a Group Number 1-S. Refer to NZBC Acceptable Solutions C/AS1 and C/AS2 to determine where the Knauf Glasswool Insulation may be used according to its Group Number.
- 11.2 Knauf Glasswool Insulation may or may not need to be enclosed by an internal lining, depending on the Risk Group. The NZBC Building Product Specifications provides specified performances [Group Number] for some generic substrate and coating combinations, including concrete, sheet metal, fibre cement, gypsum plasterboard and wood substrates.

External Moisture

- 12.1 The total building envelope must be weathertight and comply with the requirements of NZBC Clause E2 to ensure that the insulation remains dry in use.
- 12.2 The moisture content of the construction materials at the time of installing and enclosing the insulation must meet the requirements of NZBC Acceptable Solution E2/AS1 or lower moisture content if required by the lining manufacturer.

Internal Moisture

- 13.1 Buildings must provide an adequate combination of thermal resistance, ventilation and space temperature to all habitable spaces, bathrooms, laundries and other spaces where moisture may be generated or may accumulate. This does not apply to communal non-residential, commercial, industrial outbuildings or ancillary buildings.
- 13.2 NZBC Acceptable Solution E3/AS1 provides an Acceptable Solution for compliance with internal moisture requirements and details on minimum ventilation and wall and ceiling insulation levels to meet these requirements

Energy Efficiency

- 14.1 Knauf Glasswool Insulation will contribute to meeting the requirements of NZBC Clause H1, Performance H1.3.1 [a] and H1.3.2 E, by compliance with NZBC Verification Methods H1/VM1, H1/VM2, NZBC Acceptable Solutions H1/AS1 or H1/AS2. Refer to Paragraphs 7.1-7.11.
- 14.2 Knauf Glasswool Insulation R-values have been determined by BRANZ testing to AS/NZS 4859.1 and are given in Table 1.

Installation Information

Installation Skill Level Requirement

- 15.1 All design and building work must be carried out in accordance with the Knauf Glasswool Insulation Technical Literature and this Appraisal. All building work must be undertaken by competent and experienced tradespeople conversant with Knauf Glasswool Insulation.

General

- 16.1 Installation of Knauf Glasswool Insulation must be in accordance with the Technical Literature and this Appraisal. NZS 4246 should be used as a guide for installing insulation in residential buildings.
- 16.2 Knauf Glasswool Insulation must be installed only when the building is enclosed and when the construction materials have achieved the required maximum moisture content or less.
- 16.3 Knauf Glasswool Insulation must be released from the packaging and allowed to re-loft prior to installation. The time to loft will depend upon the length of time the product has been packaged and stored.
- 16.4 Knauf Glasswool Insulation is supplied in segments, blanket and roll form [refer to Table 1] to suit framing layouts. The segment products are sized to fit between standard framing centres. The products are able to be cut to suit wall cavities and when fitted between roof or ceiling framing. The insulation must be neatly friction-fitted between framing members so that the potential for gaps and convective heat loss is reduced. In wall cavities, the insulation must be neatly friction-fitted between framing members to prevent sagging. In ceilings or roofs, the insulation may be fitted between framing members or fitted over framing members and butted tightly. The insulation must extend to the external wall plate. The insulation must not be folded, tucked or compressed. A close, even fit provides the most efficient thermal performance. Whenever possible, the insulation should be fitted beneath wiring or plumbing.
- 16.5 For new and existing buildings, the R7 and R8 ceiling products are designed to be friction-fitted between framing and spill above the framing to form a uniform insulation layer on the top.
- 16.6 The clearance requirements for heating appliances and downlights must be followed. Refer also to NZS 4246.

Inspections

- 16.7 The Technical Literature, this Appraisal and NZS 4246 must be referred to during the inspection of Knauf Glasswool Insulation installations.

Health and Safety

- 17.1 Refer to the Technical Literature and NZS 4246 for guidance on health and safety requirements such as personal protective clothing and installation hazard assessment.

Basis of Appraisal

The following is a summary of the technical investigations carried out:

Tests

- 18.1 BRANZ has carried out assessments of thermal resistance testing of Knauf Glasswool Insulation in accordance with AS/NZS 4859.1.
- 18.2 Tests have been carried out in accordance with AS 1530.1. Knauf Glasswool Insulation is not deemed combustible according to the test criteria. The results have been reviewed by BRANZ technical experts.

Other Investigations

- 19.1 An assessment of the durability of Knauf Glasswool Insulation has been made by BRANZ technical experts.
- 19.2 The Technical Literature has been reviewed by BRANZ and found to be satisfactory.
- 19.3 The fibre used to manufacture Knauf Glasswool Insulation is certified to the European Certification Board for Mineral Wool Products [EUCEB].

Quality

- 20.1 The manufacture of Knauf Glasswool Insulation has been examined by BRANZ, including methods adopted for quality control. Details of the manufacturing processes, and quality and composition of the raw materials used were obtained and found to be satisfactory.
- 20.2 Knauf Insulation Pty Limited is responsible for the quality of the product supplied.
- 20.3 Quality of installation of the product on-site is the responsibility of the installer.
- 20.4 Quality of maintenance of the building to ensure the insulation material remains dry is the responsibility of the building owner.

Sources of Information

- AS 1530.1:1994 Combustibility test for materials.
- AS/NZS 4859.1:2018 Thermal insulation materials for buildings.
- BRANZ Bulletin Number 610 Preventing moisture problems in timber-framed skillion roofs.
- BRANZ House Insulation Guide [Sixth Edition], 2022.
- NZS 4214:2006 Method of determining the total thermal resistance of parts of buildings.
- NZS 4246:2016 Energy efficiency – Installing bulk thermal insulation in residential buildings.
- Ministry of Business, Innovation and Employment Record of amendments – Acceptable Solutions, Verification Methods and handbooks.
- The Building Regulations 1992.

Amendments

Amendment No. 1, dated 09 January 2023

This Appraisal has been amended to incorporate changes to Table 1 and reflect the new NZBC H1 Energy Efficiency regulations.

Amendment No. 2, dated 01 September 2026

This Appraisal has been amended to update the Product Range in Table 1, update the Technical Literature and to reflect the changes made to the NZBC compliance documentation.




In the opinion of BRANZ, **Knauf Glasswool Insulation** is fit for purpose and will comply with the Building Code to the extent specified in this Appraisal provided it is used, designed, installed and maintained as set out in this Appraisal.

The Appraisal is issued only to **Knauf Insulation Pty Limited**, and is valid until further notice, subject to the Conditions of Appraisal.

Conditions of Appraisal

1. This Appraisal:
 - a) relates only to the product as described herein;
 - b) must be read, considered and used in full together with the Technical Literature;
 - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
 - d) is copyright of BRANZ.
2. **Knauf Insulation Pty Limited:**
 - a) continues to have the product reviewed by BRANZ;
 - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
 - c) abides by the BRANZ Appraisals Services Terms and Conditions;
 - d) warrants that the product and the manufacturing process for the product are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ pursuant to BRANZ's Appraisal of the product.
3. BRANZ makes no representation or warranty as to:
 - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and workmanship;
 - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
 - c) any guarantee or warranty offered by **Knauf Insulation Pty Limited**.
4. Any reference in this Appraisal to any other publication shall be read as a reference to the version of the publication specified in this Appraisal.
5. BRANZ provides no certification, guarantee, indemnity or warranty, to **Knauf Insulation Pty Limited** or any third party.

For BRANZ



Chelydra Percy

Chief Executive

Date of Issue:

02 August 2022